

3/4" Conduit Hub

0

Release.

11/14/00

A

See ECR #50825-01

9/16/05

Test Point (-)

Factory Set Potentiometer

Zero Potentiometer

Span Potentiometer

Interconnect Terminal Strip

Test Point (+)

Carbon Monoxide Amplifier

Securing Screw (2)

Detector Housing

Detector Housing Cap

Flame Arrestor Guard
(permanently bonded to cap)

Jumper Block Installed To Toxic
Select Header.

Detector Terminal Strip

Carbon Monoxide
Detector

TOLERANCES: (IF NOT STATED)
.XX ----- +/- .010
.XXX ----- +/- .005

ALL DIMENSIONS IN INCHES UNLESS
OTHERWISE STATED.

MATERIAL: N/A

FINISH: N/A

SCALE: 1:3



RKI Instruments, Inc.
www.rkiinstruments.com

TITLE:
Component location, conduit mounting CO detector/xmtr with Flame
Arrestor Guard

A

DRAWN BY:
MF/CW

PART NUMBER:
65-2432RK-05-R03

REVISION:
A

APPROVED BY:

DATE: 11/14/00

PAGE 1 OF 1